

APPENDIX A

- Part 1 – Incidence of arson and fire
- Part 2 – Environment and buildings
- Part 3 – Effectiveness of fire safety and fire protection measures
- Part 4 – The consequences of a fire

2.7 A score of 0-5 is assigned to each question with 0 being low risk and 5 being high risk. The four main sections are then split into two main categories: parts 1 and 2 combined and parts 3 and 4 combined. The scores from the two categories are then added together to gain the overall risk. The risk levels are as set out in the table below:-

Proposed overall scoring		<i>Proposed scoring Parts 1 and 2</i>		<i>Proposed scoring Parts 3 and 4</i>	
Low risk	0 – 40	<i>Low risk</i>	<i>0 – 20</i>	<i>Low risk</i>	<i>0 – 20</i>
Average risk	41 – 100	<i>Average risk</i>	<i>21 – 60</i>	<i>Average risk</i>	<i>21 – 50</i>
High risk	101 – 230	<i>High risk</i>	<i>61 – 85</i>	<i>High risk</i>	<i>51 – 145</i>

2.8 Once the overall score has been established the risk assessment tool makes the following recommendations:

Low Risk - The fire safety and fire protection survey and risk assessment indicates the school is at a low level of risk. Sprinklers may be beneficial.

Average Risk –The fire safety and fire protection survey and risk assessment indicates the school is at an average risk. A sprinkler system is recommended.

High Risk - The fire safety and fire protection survey and risk assessment indicates the school is at a high risk. Sprinklers should be provided.