



NOTE
 This drawing is to read in conjunction with all other Architects drawings and all Structural Engineers drawings details and calculations.
 It is the contractors responsibility to check all dimensions prior to fabrication or construction, any discrepancies to be reported to the Architect.

- KEY**
- LICENSED AREA
- FIRE AUTHORITY REQUIREMENTS**
- F30 HALF HOUR FIRE RESISTANT WITH SMOKE SEALS & INTUMESCENT STRIPS
 - F60 ONE HOUR FIRE RESISTANT WITH SMOKE SEALS & INTUMESCENT STRIPS
 - VP VISION PANEL
 - PB PANIC BOLT
 - SC SELF-CLOSING
 - SCA SELF-CLOSING AUTOMATIC RELEASE
 - FL FUSIBLE LINK
 - DS DOOR SELECTOR
 - S14 "FIRE DOOR KEEP LOCKED" 10mm LETTERS TO BOTH SIDES OF DOOR LEAF
- ILLUMINATED MAINTAINED "FIRE EXIT" SIGN
 - AREA COVERED BY ESCAPE LIGHTING TO BS.5266, PART 1
 - AREA COVERED BY SMOKE DETECTORS-BSEN 54-7
 - AREA COVERED BY HEAT DETECTORS
 - FIRE ALARM CALL POINT
 - FIRE ALARM INDICATOR PANEL
 - FIRE BLANKET IN CONTAINER
 - CARBON DIOXIDE FIRE EXTINGUISHER
 - 9 LITRE WATER EXTINGUISHER
 - DRY POWDER EXTINGUISHER
 - FOAM FIRE EXTINGUISHER
 - ALARM WARNING DEVICE music sound system to be de-activated on alarm

MAGISTRATE NOTES
 FIRE ALARM SYSTEM TO CUT OUT MUSIC/SOUND SYSTEM ONCE ACTIVATED
 ALL WALLS AND PARTITIONS TO BE MINIMUM HALF HOUR FIRE RESISTANT
 EMERGENCY LIGHTING TO COMPLY WITH BS 5266 PART 1
 FIRE SAFETY RELATED SIGNS AND NOTICES TO COMPLY TO BS 5499
 FIRE FIGHTING EQUIPMENT TO COMPLY WITH BS 5306 WALL AND CEILING LININGS ARE TO BE CLASS 1 SURFACE SPREAD OF FLAME (AS DEFINED BY BS 476 CLASS 0 IN ESCAPE ROUTES)
 UPHOLSTERED SEATING FURNITURE TO SATISFY THE FOLLOWING
 * IGNITION SOURCE (CIGARETTE TEST) AS SPECIFIED IN BS 5852 PART 1
 * FIRE TEST FOR FURNITURE METHODS OF TEST FOR THE IGNITABILITY BY SMOKERS
 * BS 5852 PART 2 FIRE TEST FOR FURNITURE-METHODS OF TEST FOR THE IGNITABILITY OF UPHOLSTERED COMPOSITES FOR TESTING BY FLAMING SOURCE, MINIMUM TEST TO BE CRIB IGNITION SOURCE'S FABRICS THAT HAVE HAD A FLAME RETARDANT TREATMENT TO PASS THE WATER SOAK TEST AS DETAILED BY BS 5651 TEST CERTIFICATE TO BE SUBMITTED TO FIRE AUTHORITY

Revisions:
 xxx

KIRKMAN
 ARCHITECTS

PO Box 929
 ALTRINCHAM, CHESHIRE
 WA15 5QL
 TEL: 07974 254060
 WWW.KIRKMANARCHITECTS.CO.UK

Project
 Kennet Centre,
 Newbury

Drawing
 Proposed Licensing Plan

Date: DECEMBER 2018 Drawn By: — Scale: 1:100

Drawing Status: LICENSING Drawing No.: 1520-03 Rev No.: —

Licensing Plan Scale 1:100